

Seuils de conformité
Cu 1 000 µg/l
Pb 10 µg/l
Ni 20 µg/l

Bâti.H

Dépôt labo Mme Bonnet						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.O

Salle des professeurs collège						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Sanitaire filles préau lycée						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.M

Sanitaire des 300						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Préparation labo 500						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.P

Self général						
Cu	●	●				
Pb	●	●				
Ni	●	●				
	6/10	17/10	7/11	20/11	8/12	15/12

Self légumerie						
Cu	●	●	●	●	●	●
Pb	●	●	●	●	●	●
Ni	●	●	●	●	●	●
	6/10	17/10	7/11	20/11	8/12	15/12

Self marmite						
Cu	●	●	●	●	●	●
Pb	●	●	●	●	●	●
Ni	●	●	●	●	●	●
	6/10	17/10	7/11	20/11	8/12	15/12

Self réfectoire						
Cu	●	●	●	●	●	●
Pb	●	●	●	●	●	●
Ni	●	●	●	●	●	●
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.C


Infirmierie collège						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Sanitaire 1er étage						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Cité scolaire de Digoin

Historique des résultats des analyses de l’eau aux 1^{er} et 2^e jets (cuivre - plomb - nickel)

- analyses conformes aux 1^{er} et 2^e jets ● analyses non conformes aux 1^{er} et 2^e jets
● analyses non conformes au 1^{er} jet - conformes au 2^e jets ● analyses conformes au 1^{er} jet - non conformes au 2^e jets



Bâti.K

Appartement K0						
Cu		●	●	●	●	
Pb		●	●	●	●	
Ni		●	●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Appartement K1						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.Q

Gymnase lycée						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.F

Toilettes collège garçon						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.L

Administration lycée						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.G

Administration collège						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.B

Dortoir 3						
Cu	●	●		●	●	●
Pb	●	●		●	●	●
Ni	●	●		●	●	●
	6/10	17/10	7/11	20/11	8/12	15/12

Dortoir 4						
Cu	●	●		●	●	●
Pb	●	●		●	●	●
Ni	●	●		●	●	●
	6/10	17/10	7/11	20/11	8/12	15/12

Dortoir 5						
Cu	●	●		●	●	●
Pb	●	●		●	●	●
Ni	●	●		●	●	●
	6/10	17/10	7/11	20/11	8/12	15/12

Vestiaire agents de ménage						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.A

Dortoir 1						
Cu	●	●	●	●	●	●
Pb	●	●	●	●	●	●
Ni	●	●	●	●	●	●
	6/10	17/10	7/11	20/11	8/12	15/12

Dortoir 2						
Cu	●	●	●	●	●	●
Pb	●	●	●	●	●	●
Ni	●	●	●	●	●	●
	6/10	17/10	7/11	20/11	8/12	15/12

Chambre 1 BTS						
Cu	●					●
Pb	●					●
Ni	●					●
	6/10	17/10	7/11	20/11	8/12	15/12

Bâti.E

Atelier agents de maintenance						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12

Salle des professeurs lycée						
Cu			●	●	●	
Pb			●	●	●	
Ni			●	●	●	
	6/10	17/10	7/11	20/11	8/12	15/12