

Seuils de conformité
 Cu 1 000 µg/l
 Pb 10 µg/l
 Ni 20 µg/l

Bâti.H

| Dépôt labo Mme Bonnet | | | | | | |
|-----------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.O

| Salle des professeurs collège | | | | | | |
|-------------------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.M

| Sanitaire des 300 | | | | | | |
|-------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.M

| Préparation labo 500 | | | | | | |
|----------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.P

| Self légumerie | | | | | | |
|----------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Self marmite | | | | | | |
|--------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Self réfectoire | | | | | | |
|-----------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.C

| Infirmierie collège | | | | | | |
|---------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Infirmierie lycée | | | | | | |
|-------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Sanitaire 1er étage | | | | | | |
|---------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.K

| Appartement K0 | | | | | | |
|----------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Appartement K1 | | | | | | |
|----------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |


Bâti.Q

| Gymnase lycée | | | | | | |
|---------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Cité scolaire de Digoin

Historique des résultats des analyses de l'eau aux 1^{er} et 2^e jets (cuivre - plomb - nickel)

- analyses conformes aux 1^{er} et 2^e jets
- analyses non conformes aux 1^{er} et 2^e jets
- analyses non conformes au 1^{er} jet - conformes au 2^e jet
- analyses conformes au 1^{er} jet - non conformes au 2^e jet
- analyses conformes aux 1^{er}, pas de 2^e jet



Bâti.F

| Toilettes collège garçon | | | | | | |
|--------------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.L

| Administration lycée | | | | | | |
|----------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.B

| Dortoir 3 | | | | | | |
|-----------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Dortoir 4 | | | | | | |
|-----------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Dortoir 5 - évier tisanerie - robinet purge automatique | | | | | | |
|---|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Dortoir 5 - évier tisanerie - mélangeur | | | | | | |
|---|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ○ | ○ | ○ | ○ | ○ | ○ |
| Pb | ○ | ○ | ○ | ○ | ○ | ○ |
| Ni | ○ | ○ | ○ | ○ | ○ | ○ |

| Vestiaire agents de ménage | | | | | | |
|----------------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.A

| Pied de colonne dortoir vide sanitaire | | | | | | |
|--|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Dortoir 1 | | | | | | |
|-----------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Dortoir 2 | | | | | | |
|-----------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.G

| Administration collège | | | | | | |
|------------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

Bâti.E

| Atelier agents de maintenance | | | | | | |
|-------------------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |

| Salle des professeurs lycée | | | | | | |
|-----------------------------|------|-------|-------|-------|-------|------|
| | 7/01 | 23/02 | 11/03 | 23/03 | 20/04 | 4/05 |
| Cu | ● | ● | ● | ● | ● | ● |
| Pb | ● | ● | ● | ● | ● | ● |
| Ni | ● | ● | ● | ● | ● | ● |