

Seuils de conformité
Cu 1 000 µg/l
Pb 10 µg/l
Ni 20 µg/l

Bâti.H

Dépôt labo Mme Bonnet						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	●
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.O

Salle des professeurs collège						
Cu	●		●			
Pb	●		●			
Ni	●		●			
	18/05	01/06	15/06	29/06	04/09	17/09

Sanitaire filles préau lycée						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.M

Sanitaire des 300						
Cu	●		●			
Pb	●		●			
Ni	●		●			
	18/05	01/06	15/06	29/06	04/09	17/09

Préparation labo 500						
Cu	●		●			
Pb	●		●			
Ni	●		●			
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.P

Self légumerie						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	18/05	01/06	15/06	29/06	04/09	17/09

Self marmite						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	18/05	01/06	15/06	29/06	04/09	17/09

Self réfectoire						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.C

Infirmierie collège						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09


Infirmierie lycée						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Sanitaire 1er étage						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Cité scolaire de Digoin

Historique des résultats des analyses de l'eau aux 1^{er} et 2^e jets (cuivre - plomb - nickel)

- analyses conformes aux 1^{er} et 2^e jets ● analyses non conformes aux 1^{er} et 2^e jets
● analyses non conformes au 1^{er} jet - conformes au 2^e jets ● analyses conformes au 1^{er} jet - non conformes au 2^e jets
● analyses conformes aux 1^{er}, pas de 2^e jet



Bâti.K

Appartement K0						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	18/05	01/06	15/06	29/06	04/09	17/09

Appartement K1						
Cu	●	●	●	●	●	
Pb	●	●	●	●	●	
Ni	●	●	●	●	●	
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.Q

Gymnase lycée						
Cu	●	●	●	●	●	●
Pb	●	●	●	●	●	●
Ni	●	●	●	●	●	●
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.F

Toilettes collège garçon						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.L

Administration lycée						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.B

Dortoir 3						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Dortoir 4						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Dortoir 5 - évier tisanerie - robinet purge automatique						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Dortoir 5 - évier tisanerie - mélangeur						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Vestiaire agents de ménage						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.A

Dortoir 1						
Cu	●				●	
Pb	●				●	
Ni	●				●	
	18/05	01/06	15/06	29/06	04/09	17/09

Dortoir 2						
Cu	●		●			
Pb	●		●			
Ni	●		●			
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.G

Administration collège						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Bâti.E

Atelier agents de maintenance						
Cu	●		●		●	
Pb	●		●		●	
Ni	●		●		●	
	18/05	01/06	15/06	29/06	04/09	17/09

Salle des professeurs lycée						
Cu			●		●	
Pb			●		●	
Ni			●		●	
	18/05	01/06	15/06	29/06	04/09	17/09